

ORDINANCE 18-04
AN ORDINANCE AMENDING FIRE CODE ORDINANCE 18-02 FOR THE
WARRENVILLE FIRE PROTECTION DISTRICT,
DUPAGE COUNTY, ILLINOIS

WHEREAS, The Warrenville Fire Protection District (The District), DuPage County, Illinois is a fire protection district duly incorporated under the laws of the State of Illinois, including the Fire Protection District Act (the "Act", 70 ILCS 705/0.01 et seq.); and

WHEREAS, the Board of Trustees of the District (the "Board") has full power pursuant to Section 6 of the Act (70 ILCS 705/6) to pass necessary ordinances, and rules and regulations for the proper management and conduct of the business of the Board for carrying into effect objects for which the District was formed; and

WHEREAS, Section 11 of the Act (70 ILCS 705/11) empowers and makes it the legal duty and obligation of the District's Board as nearly adequate protection from fire for all persons and property within the District as possible to prescribe necessary regulations for the prevention and control of fire therein; and

WHEREAS, the District's Board has the expressed power pursuant to section 11 of the Act (70 ILCS 705/11) to adopt and enforce fire prevention codes and standards parallel to national standards to promote fire prevention; and

WHEREAS, the District is empowered by the Act to provide reasonable safeguards through Fire Prevention Codes to protect the Public Health and Safety against hazards of the buildings and structures; and

WHEREAS, Pursuant to said authority the Board adopted Ordinance 18-02 as on May 16, 2018 entitled "AN ORDINANCE ESTABLISHING A SET OF CODE AMENDMENTS TO ORDINANCE 16-05 FOR THE WARRENVILLE FIRE PROTECTION DISTRICT"; and

WHEREAS, the need has come to amend Ordinance 18-02 to add further clarification to the original fire code ordinance.

SECTION ONE Amendments to Fire Code Ordinance 18-02

Section 907.2 INSERTIONS, DELETIONS; delete "licensed" and replace with "UL Listed" and add "Local" – to read as follows: Alarm to be monitored by a local UL Listed Central Station or Local Remote Station and dispatched by approved AES/Keltron radio transmitter.

New structures shall install an approved addressable contact point I.D. fire alarm system in accordance of this code and NFPA 72, and provide occupant notification in accordance with section 907.5. Fire Alarm system shall only include that necessary for required operation and not include other components for security or burglar alarm functions. Alarm to be monitored by a local UL Listed Central Station or Local Remote Station and dispatched by approved AES/Keltron radio transmitter.

Section 907.6.7 **INSERTIONS, DELETIONS;** Delete "licensed" and add "Local" – to read: **Any current installed and operating local fire alarm systems in all use groups must be properly monitored by a local, UL listed Central station or Local Remote Station.**

§ 101 REPEALER

All portions of Ordinances of the Warrenville Fire Protection District inconsistent herewith, to the extent of such inconsistency and no further, are hereby repealed upon the effective date hereof.

§ 102 SEVERABILITY

Should any section, subsection or other provision of this ordinance for any reason to be held invalid or unconstitutional by the decision of any court of competent jurisdiction, such decision shall not affect the validity of the Ordinance as a whole or any part not declared invalid.

§ 103 SAVINGS CLAUSE

That nothing in this Ordinance or in the Codes hereby adopted shall be construed to affect any suit or proceeding impending in any court, or any rights acquired, or liability incurred, or any cause or causes of action acquired or existing, under any act or ordinance hereby repealed as cited in Section 5; nor shall any just or legal right or remedy of any character be lost, impaired or affected by this Ordinance.

§ 104 EFFECTIVE DATE

That this Ordinance 18-04 shall be in full force and effect from and after its passage, approval, and publication to pamphlet form and following completion of all other publication requirements as provided by law.

AYES: 5
NAYS: 0
ABSENT: 0

PASSED and APPROVED this 21st day of November, 2018.


Kathleen Perkins, President

ATTEST:


Jeff Carstens, Secretary

STATE OF ILLINOIS)
)
COUNTY OF DUPAGE)

SS

SECRETARY'S CERTIFICATE

I, Jeff Carstens Secretary of the Board of Trustees of the Warrenville Fire Protection District, DuPage County, Illinois, do hereby certify that attached hereto is a true and correct copy of that certain Ordinance now on file in my office entitled:

ORDINANCE NO. 18-04

**AN ORDINANCE AMENDING FIRE CODE ORDINANCE 18-02 FOR THE
WARRENVILLE FIRE PROTECTION DISTRICT,
DUPAGE COUNTY, ILLINOIS**

which said Ordinance was adopted by the Board of Trustees of the Warrenville Fire Protection District at a regular meeting held on the 21st day of November, 2018.

I do further certify that a quorum of said Board of Trustees was present at said meeting, and that the Board of Trustees complied with all the requirements of the Illinois Open Meetings Act.

IN WITNESS WHEREOF, I have hereunto set my hand this 21st day of November, 2018.



Jeff Carstens, Secretary
Board of Trustees
Warrenville Fire Protection District

(SEAL)