

# WARRENVILLE FIRE PROTECTION DISTRICT

3S472 Batavia Road, Warrenville, IL 60555

TEL: 630-393-2175 FAX: 630-393-4608

## MOBILE FOOD TRUCK/TRAILER CHECKLIST

DATE:

TO:

Copy:

WFPD PLAN REVIEW BY: Fire Marshal C Voda

[vodac@warrenvillefire.com](mailto:vodac@warrenvillefire.com)

PROPOSED BUILDING:

---

- DuPage County Health Department Permit
- City of Warrenville Business License
- Warrenville Fire Protection District Inspection
- Clearance from Buildings/Vehicles/Structures **IFC 3103.1, #2.3**
- Fire Department Access Fire Lane **IFC Chapter 503, and 3103.8.1**
- Proper Ventilation Exhaust System required **NFPA 96, 4.1, IFC 609**
- Cooking creating Grease-Leyden Vapors (Deep Fat Fryers, Ranges, Griddles, Broilers, Woks, Braising Pans, and Skillets) IFC 609, 904, NFPA 96 Chap **4&10.**
- Type 1 Hood and Automatic Fire Extinguishing system UL 300 required.
- Solid Fuel Cooking **NFPA 96 Chapter 4&14**
- UL 300 Automatic Extinguishing System/Hood and Class K extinguisher Req.
- Inspection **NFPA 96 10.9 and Chapter 11, NFPA 10, IFC 906, 904.12**
- Portable 10# A-B-C Fire Extinguisher Req. Inspection **NFPA 10, IFC 906.**
- Use of Portable Generator for Power Shall meet **IFC 313** with proper distance requirements (No gasoline to be carried on vehicle)
- Unobstructed access to Fire Hydrants maintained at all times **IFC 507.5.4**
- LP usage and storage to meet **NFPA 58 (Liquid Petroleum Gas Code, Chapter 6)**
- Storage of trash, objects, equipment, tables and chairs, etc., Shall not obstruct Fire Equipment Access **IFC 509.2**
- No Open Flame Cooking permitted under tents. Open Air Grills must be placed outside and clear of tents, Propane tank storage not permitted under tents and must maintain a 10' setback. Hot cooking surfaces shall be protected and separated from Public/Children.