

STATE OF ILLINOIS)
)
COUNTY OF DUPAGE) SS

SECRETARY'S CERTIFICATE

I, **KENNETH McNATT**, the duly qualified and acting Secretary of the Board of Trustees of the Warrenville Fire Protection District, DuPage County, Illinois, do hereby certify that I am the keeper of its books and records and that the attached hereto is a true and correct copy of an Ordinance entitled:


ORDINANCE NO. 02-05

AN ORDINANCE TO AMEND WARRENVILLE FIRE PROTECTION DISTRICT ORDINANCE NO. 93-2 (Fire Code)

which Amendment was duly adopted by said Board of Trustees at a meeting held on the 12th day of August, 2002.

I do further certify that a quorum of said Board of Trustees was present at said meeting and that the Board complied with all requirements of the Illinois Open Meetings Act.

IN WITNESS WHEREOF, I have hereunto set my hand this 12th day of August, 2002.



Kenneth McNatt, Secretary
Warrenville Fire Protection District

ORDINANCE #02-05

WARRENVILLE FIRE PROTECTION DISTRICT
DU PAGE COUNTY, ILLINOIS

ORDINANCE TO AMEND WARRENVILLE FIRE PROTECTION DISTRICT
ORDINANCE #93-2 (Fire Code)

WHERE AS, the Warrenville Fire Protection District had previously adopted a fire prevention code in order to protect its residents from the threat of fire and associated hazards; and

WHEREAS, Fire District Board of Trustees believe, and hereby declare, that it is in the best interests of the Fire District and its residents to amend the aforesaid code;

WHEREAS, The Board of Trustees of Warrenville Fire Protection District, DuPage County has express power pursuant to 70 ILCS 705/11, to adopt and enforce fire prevention codes and standards parallel to national standards to promote fire prevention; and

NOW, THEREFORE, BE IT ORDAINED BY THE WARRENVILLE FIRE PROTECTION DISTRICT, DU PAGE COUNTY, ILLINOIS, AS FOLLOWS:

The following provisions shall be added and incorporated into the Warrenville Fire Protection District Fire Prevention Code

Sec. F-313.0 Fire lanes

F-313.1 Public Access and Fire Lanes on Private Property, Devoted to Public Use.

F-313.1 #2 revise to read:

2. Public or private access for motor fire apparatus shall be provided around the building so that there may be proper operation of ladders and mechanically elevated mechanisms. Minimum width of the fire lanes shall be 18 feet with greater widths to accommodate vehicles when turning and laddering buildings.

F-313.1 #6 revise to read:

6. Access roads shall be not less than five (5) feet from the outer perimeter of the building and further if the height of the building requires a greater set back to ladder the buildings or a distance approved from the Chief of the Warrenville Fire Protection District.

F-313.1 #7 revise to read:

7. Access routes shall be continuous around the building.
 - a. This requirement may be modified by the Fire Official where adequate building access opening and a complete fire suppression system are provided.

- b. Where cul-de-sacs are permitted, they shall not be less than one hundred twenty (120) feet in diameter, where the length of the dead end roadway exceeds three hundred (300) feet in length for other than detached single family construction.
- c. Where cul-de-sacs are permitted, they shall not be less than one hundred (100) feet in diameter, non-dependant on the length of the dead end roadway for detached single family construction.

Sec. F-319.0 Fire Department Rapid Entry System.

Sec. F 319.3 Location revised to read

Sec. F 319.3 Location. The installation of the approved knox box shall be approved by the Chief of the Warrenville Fire Protection District and be at a height no more than eighty (80) inches to top of knox box from finished grade.

This Ordinance shall be in full force and effect from and after its approval and publication in accordance with the law.

ADOPTED this 12th day of August, 2002 by the following roll call vote:

AYES: 3


NAYS: X

ABSENT: X



Clifford Johnson
President, Board of Trustees
Warrenville Fire Protection District

ATTEST:



Kenneth McNatt
Secretary, Board of Trustees
Warrenville Fire Protection District