

**ORDINANCE 18-02
AN ORDINANCE ESTABLISHING
A SET OF CODE AMENDMENTS TO ORDINANCE 16-05 FOR THE WARRENVILLE
FIRE PROTECTION DISTRICT,
DUPAGE COUNTY, ILLINOIS**

WHEREAS, The Warrenville Fire Protection District (The District), DuPage County, Illinois is a fire protection district duly incorporated under the laws of the State of Illinois, including the Fire Protection District Act (the "Act", 70 ILCS 705/0.01 et seq.); and

WHEREAS, the Board of Trustees of the District (the "Board") has full power pursuant to Section 6 of the Act (70 ILCS 705/6) to pass necessary ordinances, and rules and regulations for the proper management and conduct of the business of the Board for carrying into effect objects for which the District was formed; and

WHEREAS, Section 11 of the Act (70 ILCS 705/11) empowers and makes it the legal duty and obligation of the District's Board as nearly adequate protection from fire for all persons and property within the District as possible to prescribe necessary regulations for the prevention and control of fire therein; and

WHEREAS, the District's Board has the expressed power pursuant to section 11 of the Act (70 ILCS 705/11) to adopt and enforce fire prevention codes and standards parallel to national standards to promote fire prevention; and

WHEREAS, the District is empowered by the Act to provide reasonable safeguards through Fire Prevention Codes to protect the Public Health and Safety against hazards of the buildings and structures; and

WHEREAS, Pursuant to said authority the Board adopted Ordinance 16-05 as on November 16, 2016 entitled "AN ORDINANCE ADOPTING BUILDING AND FIRE PREVENTION CODES FOR THE WARRENVILLE FIRE PROTECTION DISTRICT"; and

WHEREAS, the need has come to amend Ordinance 16-05 to add further clarification and support to the original fire code ordinance.

§ 100. INCORPORATION

That the preambles to this Ordinance be and the same hereby are, incorporated herein by this reference as if set out in full at this place.

§ 101. RULES OF CONSTRUCTION

The language of this Ordinance shall be interpreted in accordance with the following rules of construction:

- A. The singular number includes the plural number includes the singular;
- B. The word "shall" is mandatory; the word "may" is permissive; and
- C. The masculine gender includes the feminine and neuter.

§ 102. DEFINITIONS.

- A. Whenever the word "municipality" is used in this code, it means the Warrenville Fire Protection District.
- B. Whenever the term "fire code official", "authority having jurisdiction", or "fire prevention bureau" is used in this code, it means the Fire Chief or his designee.
- C. Whenever the term "department of building or fire" is used in this code, it means the Fire Prevention Bureau of the Warrenville Fire Prevention Bureau.
- D. Whenever the term "structure" or "building" is used in this code it shall have the same meaning as defined in the ICC International Building Code – 2015 Edition.

§ 103. SHORT TITLE

This Ordinance shall be known and cited as the "Fire and Building Code" and will be referred to in this Ordinance as "the code" or the "building code."

§ 104. Appeals

(a) An appeal may be taken to the Warrenville Fire Protection District by applying to the Warrenville Fire Protection District Board by any person aggrieved, from any order, requirement decision or determination made by the Fire Official or his/her assigned designee. Such appeal shall be taken within 20 days of the action from which it is taken by filing with the Fire Official, a notice of appeal, specifying the grounds thereof. The Board shall thereupon set a reasonable time, date and place certain for a hearing of said appeal, and shall cause written notice thereof to be mailed to the appealing party, or his/her attorney, and to the Fire Official.

(b) The Board may reverse or affirm, wholly or partially, or may modify the order, requirement decision or determination as in its opinion ought to be done or made in the premises, and to that end shall have all the powers vested to the Fire Official by this Ordinance.

(c) The vote of the majority of the members of the Board present shall be necessary to reverse, in whole, or in part or to modify, any orders, requirements, decisions or determinations of the Fire Official. The Board shall keep minutes of its proceeding hereunder, showing the vote of each member upon every question, or if absent or failing to vote, indicating such fact, and shall also keep records of its examinations and other official acts.

(d) All decisions of the Board hereunder shall be reduced to writing, filed with the Clerk, and a copy thereof mailed to the appealing party and to the Fire Official.

(e) As used in this Ordinance the term Fire Official means the person or corporation appointed by the President and approved by the Board of Trustees.

§ 105 Violations – penalties: remedies

(a) It shall be unlawful for any person, firm or corporation to erect, construct, alter, extend, repair, move, remove, demolish or occupy any building, structure or equipment regulated by this code, or cause same to be done, in conflict with or in violation of any of the provisions of this code.

(b) The Fire Official is authorized to serve a notice of violation or order on the person responsible for the erection, construction, alteration, extension, repair, moving, removal, demolition or occupancy of a building or structure in violation of the provision of this code, or in violation of a permit or certificate issued under the provisions of this code. Such order shall direct the discontinuance of the illegal action or condition and the abatement of the violation.

(c) If the notice of violation is not complied with promptly, the Fire Official is authorized to request the Board Attorney to institute the appropriate administrative proceeding and/or proceeding at law or in equity to restrain, correct or abate such violation, or to require the removal, termination of the unlawful occupancy of the building or structure in violation of this code or of the order or direction made pursuant thereto, and to punish such violator in accordance herewith.

(d) Any person who violates, disobeys, omits, neglects or refuses to comply with, or who resists the enforcement of any of the provisions of this ordinance, including provisions adopted by reference, or who refuses to remedy a violation of any such provision or to remedy a hazard of fire, explosion, collapse, contagion, or spread of infectious disease found to exist and duly ordered eliminated, shall be guilty of an offense under this ordinance and shall pay a civil fine not to exceed \$750. Each day's continuing violation shall constitute a separate offense. If it should become necessary to institute legal action to enforce the provisions of this ordinance, or to restrain a violation hereof; or to collect any fees imposed by the Fire Official hereunder, the Board, in addition to the imposition of such remedy, shall be entitled to an award of all its costs and expenses incurred in such action, including its reasonable attorney's fees.

(e) A person licensed or registered by the state, or a subdivision thereof, to do work regulated by this ordinance or to render professional, architectural, or engineering service in connection therewith, who violates the law or ordinance under license or registration, or who violates the ordinance while carrying out such work or rendering service in connection therewith, shall be reported to the Fire Official and to the licensing authority.

(f) Where a dispute arises regarding an engineering opinion furnished by the owner of property involved in such manner covered by this ordinance, the Board may engage the services of a qualified registered engineer and the owner of the property involved by way of an increase in the application fee otherwise provided, shall reimburse the Board for reasonable customary cost of such services. In the event the property owner prevails, the District shall absorb costs pertaining to the engineering costs and fees generated in such dispute.

§ 106 Stop work order

(a) Whenever the Fire Official finds any work regulated by the code being performed without a permit or in a manner either contrary to the provisions of this code or dangerous or unsafe, the Fire Official is authorized to issue a stop work order.

(b) The stop work order shall be in the form of a red-tag posted on the building or property involved, or given to the owner's agent, or to the person doing the work. Upon posting the red-tag the cited work shall immediately cease.

(c) Any person who shall continue any work after the building or property has been red-tagged, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties prescribed in this ordinance.

§ 107 Plumbing in general

(a) Delete all references in all ICC codes to the International Plumbing Code and insert the Illinois Plumbing Code.

§ 108 Other codes in general

(a) NFPA the following standards are adopted by reference and supersede the editions listed in of the adopted codes
NFPA 13 – 2016 Standard for the installation of Sprinkler systems
NFPA 13R - 2016 Standard for the installation of Sprinkler Systems in Low Rise Residential Occupancies
NFPA 13D - 2016 Standard for the Installation of Sprinkler Systems in One and Two Family Dwellings
NFPA 101 – 2015 Life Safety Code
NFPA 72- 2016 National Fire Alarm and Signaling Code

(b) DuPage County Fire Prevention Code – 2015 edition

§ 109 Adoption of codes

ADOPTION OF CODES.

That the codes described and as set forth below in this section, three (3) copies of which are on file in the offices of the Warrenville Fire Protection District, are hereby adopted as the Building Code of the Warrenville Fire Protection District, in the State of Illinois, for the control of buildings and structures as herein provided; and each and all of the regulations, provisions, penalties, conditions and terms of said Codes are hereby referred to, adopted and made a part hereof, as if fully set out in this ordinance with the additions, insertions, deletions and changes, if any, prescribed in this Ordinance, excepting there from any conflict with the Warrenville Fire Protection District fee schedule ordinance. The following Codes are adopted:

- | | |
|--|--------------|
| 1. International Building Code | 2015 Edition |
| 2. International Residential Code | 2015 Edition |
| 3. International Mechanical Code | 2015 Edition |
| 4. International Fuel Gas Code | 2015 Edition |
| 5. International Property Maintenance Code | 2015 Edition |

6.	International Fire Code	2015 Edition
7.	International Urban-Wildland Interface Code	2015 Edition
8.	International Existing Building Code	2015 Edition
9.	International Energy Conservation Code	2015 Edition
10.	International Swimming Pool and Spa Code	2015 Edition
11.	International Solar Energy Provisions	2015 Edition
12.	National Electric Code	2014 Edition
13.	Illinois Plumbing Code	2014 Edition
14.	Illinois Accessibility Code	1997 Edition
15.	NFPA 101 Life safety Code	2015 Edition

Code conflicts: When there is conflict between one of the adopted codes or the code and referenced standards, the stricter of the requirements shall apply.

§ 110 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL BUILDING CODE

Chapter 1: Administration

The following sections are hereby revised as follows:

Section 101.1 Insert: "Warrenville Fire Protection District"

Section 105.1.7 Insert: **Permit Fees.** Fees are per the applicable Warrenville Fire Protection District, City of Warrenville, or DuPage County schedules.

Section 109.2 Add the following: See the Warrenville Fire Protection District fees

Section 112.2 See section 104 of this ordinance for Board membership.

Section 113.6 Add the following: See the Warrenville Fire Protection District fees schedule.

Section 304.1.1.1 Insert: **Waste Material.** "No person shall store in any building excess packing cases, wooden or plastic pallets, barrels, boxes, rubber tires, shavings, excelsior, rubbish, paper bags, litter, hay, straw and similar combustibles. Aisle ways and storage of the above mentioned combustibles necessary for the performance of business shall be kept in an orderly and neat manor. Combustible materials shall be removed daily or more often as necessary to suitable vaults, bins, dumpsters, compactors or separate building. Such practices shall be approved by the code official.

Section 319 Insert: **319.1 Transportation.** Routes for vehicles transporting explosives, blasting agents, and combustible & flammable liquids shall be approved by State and Federal governments.

Section 503.2.4 Add: "Approved turning radius templates shall be shown on all documental submittals."

Section 503.4.2 Insert: **Enforcement agreement required.** Where required to ensure enforcement of parking restrictions the building or property owner shall enter into an enforcement agreement with the police department allowing issuance of citations.

Section 505.1 Add: **Address numbers.** Similar sized numbers and letters shall be located at all rear and side doors of all multi-tenant commercial structures.

Section 506.1 Add: **Where required.** This rapid entry key box system shall be used for Fire Department Emergencies only.

Section 507.5.1 **Where required. Delete in its entirety including exceptions and substitute the following;**

Insert. Where required. Along public streets so that no portion of the building or structure to be protected will be over three hundred (300) feet from any required hydrant in multiple-housing, commercial, or industrial developments as measured along approved route and four hundred (400) feet in residential districts. Where this may not be possible, additional hydrants shall be located upon the premises accessible to motorized fire apparatus.

Section 507.5.1.2 Insert: **Distance to fire department connection (FDC).** No required FDC shall be located over fifty (50) feet from a Fire Hydrant.

Section 507.5.1.3 Insert: **Where required.** At least two (2) hydrants shall be located within three hundred (300) feet of each commercial or multifamily building.

Section 507.5.7 Insert: **Design standard.** Fire hydrants used in conjunction with water supplies shall meet the standard of the American Water Works Association Standard No. C-502, and shall have two (2) 2-1/2 inch and one (1) 4-1/2 inch outlets. Threads shall be American National Standard. The 4-1/2 inch port shall face the roadway. Each fire hydrant shall supply one thousand (1000) gpm, and where fire suppression systems are served by the same main, the system requirement shall be added to the total water supply requirement.

Section 903.2 **Automatic sprinklers where required:** Delete 903.2 through 903.2.10.1 and replace as follows: **Approved automatic sprinklers systems shall be installed in all new building groups, A,B,E,F-1,F-2,H,I,R (by amendment below), M,S-1,S-2 and group U exceeding 1,000 square feet.**

All One and Two Family dwellings shall have a fire sprinkler system when the following are applicable:

1. Lot size is less than 7,000 square feet and
2. When any part of the structure is two stories or greater or any part of the roof structure is greater than 30 feet and has a lot coverage of less than 33% as defined in The Warrenville Zoning Ordinance. (High Density)

Section 903.2.13 **Additions and remodeling in excess of 50 percent of square footage to existing buildings.** Add: An automatic fire sprinkler system shall be provided throughout existing buildings and new additions as listed above, when such

additions and or remodeling's exceed 50 percent of the total square footage or a change of use of occurs if new use is of an increased hazard.

Section 903.3.7 Fire Department Connections; Add: FDC's installed shall require 5 inch Storz fitting with 30 degree elbow.

Section 903.4 Add: **Sprinkler system supervision and alarms. Exceptions: 2, 3,4,5,6, and 7 delete in their entirety.**

Section 905.3.9 Add: All other buildings. Standpipes shall be installed in areas where horizontal or vertical access is more than one hundred fifty (150) feet beyond the level of the fire department vehicle access. Distance to be measured starting from the fire department apparatus' hose connection. These are required to be located at each exit door on each floor.

SECTION 907. Fire Alarm and Detection Systems; Insert: Existing Fire alarms systems must continue to be smoke activated in all use groups, in all structures over 1500 square feet. Smoke activated Fire Alarm systems will be installed in common areas only.

Section 907.2 Where required; delete the first paragraph in its entirety and substitute the following language;

New structures shall install an approved addressable contact point I.D. fire alarm system in accordance of this code and NFPA 72, and provide occupant notification in accordance with section 907.5. Fire Alarm system shall only include that necessary for required operation and not include other components for security or burglar alarm functions. Alarm to be monitored by a local licensed Central Station or Remote Station and dispatched by approved AES/Keltron radio transmitter.

Section 907.2.1 Delete first paragraph and the exception in its entirety and substitute the following language;

907.2.1. Group A, Group E, Group H, Group I, Group M, Group R-1,R-2, . An automatic fire alarm detection system shall be installed and maintained in all new occupancies.

Section 907.2.2 Delete the first paragraph and the exception in its entirety and substitute the following language;

907.2.2 Group B. An automatic fire alarm detection system shall be installed and maintained in all new occupancies over 500 Sq. Ft.

Section 907.2.4 907.2.4 Group F. Delete this paragraph in its entirety and substitute the following language;

907.2.4 Group F,S, and U. An automatic fire alarm detection system shall be installed and maintained in all new occupancies with a total gross building area over 500 (Five Hundred) square feet.

Section 907.5 Insert. Tampering with the resetting of Fire Alarms. At no time or incident will anyone besides Fire District personnel reset the Fire Alarm System during an official Fire Alarm activation and could be subject to fines and or charges brought against per state law.

Section 907.5.2.3.4 Insert. Audio Visible Alarms Tenant space .Each tenant space in a multiple tenant building shall have an audio visual device in an outside public access area indicating which tenant space has the activated alarm.

Section 907.5.2.3.5 Insert. Outside Water flow alerting Red Lens Visual device. All fire alarm fire suppression systems shall provide a Red Lens Visual device mounted over the required FDC for all water flow activations.

Section 907.6.6 Monitoring. Delete the exceptions in their entirety.

Section 907.6.7 Insert: Installation and monitoring; Any current installed and operating local fire alarm systems in all use groups must be properly monitored by a local, licensed UL listed Central station or Remote Station.

Section 907.6.8 Insert: Existing building additions and remodeling In access of twenty five (25) percent. Add: All existing buildings regardless of use group shall install an approved automatic fire detection system when additions or remodeling that exceed twenty five (25) percent of the square footage of the building.

Section 907.9 Delete this section in its entirety and insert the following;
907.9. Where required in existing buildings and structures. An approved fire alarm system complying with this chapter shall be maintained in all existing buildings and structures currently protected, and provided in all new occupancies and structures as required..

Section 5601.2 Permit Required.

Insert. 5601.2.5. Fireworks; Shall follow the local requirements of the City of Warrenville ordinance #2291 and the Warrenville Fire Prevention District ordinance #2009-03

IEBC section 101.8 Add: Fire Protection systems. The requirements for the fire protection systems as outlined by any section of this code are superseded by the requirements in the amendments to the International Building and Fire Codes for new and existing buildings.

IEBC section 1401.5.4 Add: Sprinkler system requirements. The local sprinkler system requirements including local amendments to the International Building and Fire Codes shall apply regardless of the outcome of the performance compliance calculations from IEBC section 1401.6

Section 101.1 Insert the following: When there is a conflict between this Code and the Illinois Accessibility Code, the stricter of the two requirements shall be applied.

Section 1612.3 Insert Title 8, Chapter 5 DuPage County Storm water and Floodplain Ordinance.

Section 3001.1.1 Insert the following: All rules, law and ordinances and amendments by the Illinois Office of the State Fire Marshall shall be applicable.

Section 3301.3 Waste container. All demolition, new construction, room additions and remodeling projects shall have a dumpster or container on site which are adequate in size for the containment and disposal of all job site refuse. The dumpster or containers shall be emptied when the wastes or trash exceeds the top edge of the container.

Appendices Adopt the following appendices D, H, I, J, K,

§ 111 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL RESIDENTIAL CODE

Chapter 1: Administration

The following sections are hereby revised as follows:

- Section R101.1** Insert: "Warrenville Fire Protection District"
- Section R108.2** Add the following: See the Warrenville Fire Protection District fees schedule.
- Section R112.1** See section 104 of this ordinance for Board membership.
- Section R113.4** Add the following: See the Warrenville Fire Protection District fees schedule.
- Section 114.1** Add the following: See section 104 of this ordinance for additional Requirements.
- Section 301.2(1)** Design Criteria

Ground Snow Load	25
Wind Speed (mph)	3 second 90 normal 75
Topographic Effects	No
Seismic Design Category	C
Special wind region	No
Wind-borne debris zone	No
Seismic Design Category	A
Weathering	Severe
Frost line depth	42 inches
Termite	Moderate to heavy
Winter Design Temperature	-4 degrees
Ice Shield Underlayment	Yes
Flood Hazard	See DuPage County Storm water Ordinance
Air Freezing Index	2000
Mean Annual Temperature	50 degrees

Section 313.2

Chapters 25 – 32 delete the Chapters in their entirety.

Appendices Adopt the following appendices J.

§ 112 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL MECHANICAL CODE

Chapter 1: Administration

The following sections are hereby revised as follows:

Section 101.1 Insert: "Warrenville Fire Protection District"

Section 106.5.2 / 106.5.3
Add the following: See the Warrenville Fire Protection District fees schedule.

Section 108.4/108.5
Add the following: See the Warrenville Fire Protection District fee schedule.

Section 109 Delete 109.2 and see section 104 of this ordinance for Board membership.

§ 113 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL FUEL GAS CODE

Chapter 1: Administration

The following sections are hereby revised as follows:

Section 101.1 Insert: "Warrenville Fire Protection District"

Section 106.5.2 / 106.5.3
Add the following: See the Warrenville Fire Protection District fees schedule.

Section 108.4/108.5
Add the following: See the Warrenville Fire Protection District fee schedule.

Section 109 Delete 109.2 and see section 104 of this ordinance for Board membership.

§ 114 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL PROPERTY MAINTENANCE CODE

Chapter 1: Administration

The following sections are hereby revised as follows:

- Section 101.1 Insert: "Warrenville Fire Protection District"
- Section 103.5 See the Warrenville Fire Protection District fee schedule.
- Section 106.4 See the Warrenville Fire Protection District fee schedule.
- Section 111.2 Delete the section and insert see section 104 of this ordinance for Board membership.
- Section 112.4 See the Warrenville Fire Protection District fee schedule.

§ 115 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL FIRE CODE

Chapter 1: Administration

The following sections are hereby revised as follows:

- Section 101.1 Insert: "Warrenville Fire Protection District"
- Section 104.1 Fire Code Official is defined as the Fire Chief or his designee.
- Section 108.3 See section 104 of this ordinance for Board membership.
- Section 109.4 Add the following: See the Warrenville Fire Protection District fees schedule.
- Section 111.4 Add the following: See District amendment 2004-02 of this ordinance for additional requirements.
- Section 114.4 Add the following: See the Warrenville Fire Protection District fees schedule.
- Section 1103.5.3 Insert the date of adoption.
- Section 5704.2.9.6.1 See the Warrenville Zoning Ordinance for the requirements.
- Section 5706.2.4.4 See the Warrenville Zoning Ordinance for the requirements.
- Section 5806.2 See the Warrenville Zoning Ordinance for the requirements.
- Section 6104.2 See the Warrenville Zoning Ordinance for the requirements.
- Appendices Adopt the following appendices B, C, D, E, F, G, H, I, J, K, M.

§ 116 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL URBAN-WILDLAND INTERFACE CODE

Chapter 1: Administration

The following sections are hereby revised as follows:

- Section 101.1 Insert: "Warrenville Fire Protection District"
- Section 103.1 Insert Fire Prevention Bureau.
- Section 106.1 Delete 109.2 and see section 404 of this ordinance for Board membership.
- Section 109.4.7 Add the following: See the Warrenville Fire Protection fee schedule.
- Section 112.1 Add the following: See the Warrenville Fire Protection District fee schedule.

§ 117 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL EXISTING BUILDING CODE

Chapter 1: Administration

The following sections are hereby revised as follows:

- Section 101.1 Insert: "Warrenville Fire Protection District"
- Section 108.2 Add the following: See the Warrenville Fire Protection District fees schedule.
- Section 112.3 Delete 109.2 and see section 104 of this ordinance for Board membership.
- Section 113.4 Add the following: See the Warrenville Fire Protection District fee schedule.
- Section 1406.1 Add the following: Regardless of the outcome of this, it will not change the automatic sprinkler requirements outlined in the Building Code, Fire Code or the amendments in this Ordinance.

§ 118 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL SWIMMING POOL SAND SPA CODE

The following sections are hereby revised as follows:

- Section 101.1 Insert: "Warrenville Fire Protection District"

Section 105.6.2/ 105.6.3

See the Warrenville Fire Protection District fees schedule.

Section 107.4

See the Warrenville Fire Protection District fees schedule.

Section 107.5

See the Warrenville Fire Protection District fees schedule

Section 108.2

Delete 108.2 and see section 104 of this ordinance for Board membership.

§ 119 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE INTERNATIONAL SOLAR ENERGY PROVISIONS

There are no additions, insertions or changes to the International Solar Energy Provisions...

§ 120 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE NATIONAL ELETRIC CODE

There are no additions, insertions or changes to the National Electric Code.

§ 121 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE ILLINOIS PLUMBING CODE

There are no additions, insertions or changes to the Illinois Plumbing Code.

§ 122 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE ILLINOIS ACCESSIBILITY CODE

There are no additions, insertions or changes to the Illinois Accessibility Code. Any conflicts between this State Code and Chapter 11 of the International Building Code shall have the stricter of the two requirements enforced.

§ 123 ADDITIONS, INSERTIONS, DELETIONS AND CHANGES TO THE NFPA 101 – LIFE SAFETY CODE

See the International Residential Code for the requirements for automatic fire sprinklers in one and two-family dwellings.

§ 124 BUILDING CONSTRUCTION HOURS OF OPERATION.

Construction or alteration operations shall not be carried on prior to 7:00 AM or later than 7:00 PM Monday through Saturday and not carried on prior to 10:00 AM and no later than 6 PM on Sundays and holidays, unless approved in writing by the Building Official.

§ 125 REPEALER

All Ordinances of the Warrentville Fire Protection District inconsistent herewith, to the extent of such inconsistency and no further, are hereby repealed upon the effective date hereof.

§ 126 SEVERABILITY

Should any section, subsection or other provision of this ordinance for any reason to be held invalid or unconstitutional by the decision of any court of competent jurisdiction, such decision shall not affect the validity of the Ordinance as a whole or any part not declared invalid.

§ 127 SAVINGS CLAUSE


That nothing in this Ordinance or in the Codes hereby adopted shall be construed to affect any suit or proceeding impending in any court, or any rights acquired, or liability incurred, or any cause or causes of action acquired or existing, under any act or ordinance hereby repealed as cited in Section 5; nor shall any just or legal right or remedy of any character be lost, impaired or affected by this Ordinance.


§ 128 EFFECTIVE DATE

That this Ordinance 18-02 shall be in full force and effect from and after its passage, approval, and publication to pamphlet form and following completion of all other publication requirements as provided by law.

AYES: _____
NAYS: _____
ABSENT: _____

PASSED and APPROVED this 16th day of May, 2018.


Kathleen Perkins
President

ATTEST;

Jeff Carsteris
Secretary