

WARRENVILLE FIRE PROTECTION DISTRICT
DU PAGE COUNTY, ILLINOIS

ORDINANCE NO. 94-2

ORDINANCE AMENDING 93-2 WARRENVILLE FIRE PROTECTION DISTRICT
FIRE PREVENTION CODE

WHEREAS, the Warrenville Fire Protection District has previously adopted a fire prevention code in order to protect its residents from the threat of fire and associated hazards; and

WHEREAS, Fire District Board of Trustees believe, and hereby declare, that it is in the best interests of the Fire District and its residents to supplement the aforesaid code;

WHEREAS, the Board of Trustees of Warrenville Fire Protection District, DuPage County, Illinois, has the power to promote and protect the public health, safety, comfort and welfare of its citizens and to require the maintenance of buildings located within its jurisdiction reasonably safe from hazards of fire. ILLINOIS REVISED STATUTES, Chapter 127 1/2, section 21.

NOW, THEREFORE, BE IT ORDAINED BY THE WARRENVILLE FIRE PROTECTION DISTRICT, DU PAGE COUNTY, ILLINOIS, AS FOLLOWS:

The following provisions shall be added and incorporated into the Warrenville Fire Protection District Board's FIRE PREVENTION CODE:

Sec. F-518.3.2.1 Revise to read:

No alarm shall be out of service for more than twenty-four (24) consecutive hours. A fine of \$50.00 per day will be imposed on those alarms remaining out of service after a forty-eight (48) hour period.

Liability for out-of-service alarms shall be the responsibility of the service contracted to respond to repair said alarm. Once the owner/manager/alarm company has been notified, liability of the Warrenville Fire Protection District ceases for that alarm.

This Ordinance shall take effect and be fully in force after its passage, approval and publication as required by law.

THIS ORDINANCE SHALL BE IN FULL FORCE AND EFFECT 10 DAYS AFTER PUBLICATION OF THIS ORDINANCE.

PASSED THIS 11th DAY OF April, 1994.

AYES: 3

NAYS: 0

ABSENT: 0

APPROVED THIS 11th DAY OF April, 1994.

ATTEST

A. J. McHale
SECRETARY

Cliff Clark
DISTRICT PRESIDENT